

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>				1. CONTRACT ID CODE	PAGE 1	OF PAGES 2
2. AMENDMENT/MODIFICATION NO. <b>0002</b>		3. EFFECTIVE DATE <b>08/31/2012</b>		4. REQUISITION/PURCHASE REQ. NO.		5. PROJECT NO. (If applicable)
6. ISSUED BY Federal Aviation Administration Acquisition Management Branch, AAQ-530 1601 Lind Ave SW Renton WA 98057				7. ADMINISTERED BY (If other than Item 6)		
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				9A. AMENDMENT OF SOLICITATION NO. <b>DTFAWN-12-R-00154</b>		
				9B. DATED (SEE ITEM 11) <b>August 14, 2012</b>		
				10A. MODIFICATION OF CONTRACT/ORDER NO.		
CODE				10B. AWARD DATED (SEE ITEM 13)		
FACILITY CODE						

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers **IS NOT** extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation on as amended, by one of the following methods:

(a) By completing Item 8 and 15, and returning 1 copies of the amendment; (b) acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hours and date specified.

**12. ACCOUNTING AND APPROPRIATION DATA (If required)**

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority)	THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT/ORDER NO. IN ITEM 10A.
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation data, etc.) SET FORTH IN ITEM 14,	
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:	
D. OTHER (Specify type of modification and authority)	

E. IMPORTANT: Contractor **is required** to sign this document and return 1 copy to the issuing office.

**14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)**

This Amendment is hereby incorporated into this RFO for the following changes.

Answers to received questions.

Attachment 1, additional drawings.

Except as provided herein, all terms and conditions of the referenced document in Item 9A or 10A, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) <b>Darren Odegard: Contracting Officer</b>	
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	BY _____	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

Q: The performance period does not seem to consider procurement time for the Lochinvar boilers.

A: Completion date is extended until December 14, 2012. Period of Performance remains 14 calendar days.

Q: Are there any constraints on boiler down-time; do they feed terminal reheat or have any type of summer load on them? If so how does the government prefer to handle it.

A: Boilers provide hot water for the terminal reheat coils, miscellaneous fan coil units, as well as hydronic radiators located along the perimeter of the building. One boiler can serve majority of the building heating load during mild winter conditions. It is recommended that the current off-line boiler be replaced first.

Q: The SOW, Para A-5 says " the contractor shall provide all temporary services required for construction." What types of temporary service are we talking about?

A: Only required if unable to replace the off-line boiler first and if work was to be done during winter months. See note for #2 above.

Q: C-2-F says the boilers must be "compatible with existing HW system." Is there anything specific the engineer has in mind? How does the government define "compatible" in relation to the system (water quality, equipment, engineering)?

A: See note for #2 above. Must be compatible with existing equipment noted in #2.

Q: Is there a BAS that monitors boiler control points? If so has the government identified any controls compatibility issues?

A: The BAS will be updated by the government to work out compatibility issues with new boilers if any arise.

Q: The controls for this project are to be modified per the scope in Part I – Section C 1.1.C Control System 3. The only modification, other than reconnecting the new boiler, may be the addition of the boiler circulation pumps.

Can you provide a sequence of operation to include the boiler circulation pumps that are new to this project?

A: The sequence will be determined upon NTP and pre-construction meeting.

Q: Is there an existing building control contractor that will be required for this project?

A: The government will be responsible for working out coordination details with the local BAS vendor , Integrated Control System, Inc.

Q: It appears that the new flue for the new boilers will need to be an AL29C double wall stainless application. From our site visit the current flue that serves the two boilers and additional equipment is an insulated CS breeching system. This means that we will need to individually vent the new boilers with the double wall stainless and bring in new CA. This is different from what the documents state (scope of work page 6) saying that we should tie into the existing flues. Please verify if we are to run out individually.

A: Yes, please run out individually.